

SL-45, 46 Type Safety Relief Valve (Lift Type)




SL-45 Type



SL-46 Type

CONSTRUCTION



Depending on nominal diameter, the structure of the valve may be different from what is shown in the drawing.

SPECIFICATIONS

Model name	SL-45	SL-46
Code name	SL45-M□	SL46-M□
	※ Code No. of pressure division is required in □.	
Cap type	With lever	Without lever
Applicable fluid	Steam & air	Steam, air, gases & liquids
Size	15~100(½"~4")	
Fluid temperature	-5~220℃	
Set pressure range	0.035~2.0MPa	
End connection	Flanged JIS 10, 16, 20 KFF *1.	
Materials	Body(Ductile cast iron*2), Disc&seat ring(Stainless steel)	
Valve body pressure test	1.5 times of flange rated pressure, (Hydraulic)	

*1. Products with RF flange at inlet/outlet are also available.

*2. Products above 40mm in size with main body made of cast steel (SL-5,6 Type) or stainless steel (SL-5,6 Type) are also available (set pressure range may vary due to different sizes).

*3. Products with cast steel main body (SL-5,6 Type) and ASME (ANSI) Class 150, 300 flange is also available.

DIMENSIONS

Size d	Seat opening dia. D	Effective area (mm ²) π D ² /4	Lift ℓ	Face to Face		Height H		Mass(kg)	
				L ₁	L ₂	SL-45Type	SL-46Type	SL-45Type	SL-46Type
15(½")	15	18.8	0.4	75	65	174	167	4.3	4.2
20(¾")	20	31.4	0.5	80	75	198	190	4.9	4.8
25(1")	25	54.9	0.7	95	90	245	242	9	8.7
40(1½")	40	125.6	1.0	110	100	253	251	13	13
50(2")	50	204.1	1.3	120	110	297	296	20.5	20
65(2½")	65	346.9	1.7	130	120	369	365	28	28
75*(3")	75	447.4	1.9	145	135	407	403	46	44
100(4")	100	785.0	2.5	170	155	557	552	74	70

※ The connecting flange is size 80mm JIS flange.

Flange code JIS 20K

PRESSURE DIVISION (Ductile cast iron)

Code No.	Size 15mm	Size 20mm	Size 25mm	Size 40mm
1	0.035~0.07	0.035~0.07	0.035~0.07	0.035~0.07
2	Over 0.07~0.1	Over 0.07~0.1	Over 0.07~0.1	Over 0.07~0.1
3	Over 0.1~0.35	Over 0.1~0.35	Over 0.1~0.35	Over 0.1~0.35
4	Over 0.35~0.5	Over 0.35~0.5	Over 0.35~0.5	Over 0.35~0.5
5	Over 0.5~0.7	Over 0.5~0.7	Over 0.5~0.7	Over 0.5~0.85
6	Over 0.7~0.85	Over 0.7~0.85	Over 0.7~0.85	Over 0.85~1.3
7	Over 0.85~1.0	Over 0.85~1.0	Over 0.85~1.0	Over 1.3~1.6
8	Over 1.0~1.3	Over 1.0~1.6	Over 1.0~1.3	Over 1.6~2.0
9	Over 1.3~1.6	Over 1.6~2.0	Over 1.3~1.6	
A	Over 1.6~2.0		Over 1.6~2.0	

(MPa)

Code No.	Size 50mm	Size 65mm	Size 75mm	Size 100mm
1	0.035~0.07	0.035~0.07	0.035~0.07	0.035~0.07
2	Over 0.07~0.1	Over 0.07~0.1	Over 0.07~0.1	Over 0.07~0.1
3	Over 0.1~0.35	Over 0.1~0.35	Over 0.1~0.35	Over 0.1~0.35
4	Over 0.35~0.5	Over 0.35~0.5	Over 0.35~0.5	Over 0.35~0.5
5	Over 0.5~0.7	Over 0.5~0.85	Over 0.5~0.7	Over 0.5~0.7
6	Over 0.7~1.0	Over 0.85~1.0	Over 0.7~0.85	Over 0.7~0.85
7	Over 1.0~1.3	Over 1.0~1.3	Over 0.85~1.0	Over 0.85~1.0
8	Over 1.3~1.6	Over 1.3~1.6	Over 1.0~1.6	Over 1.0~1.3
9	Over 1.6~2.0	Over 1.6~2.0	Over 1.6~2.0	Over 1.3~1.6
A				Over 1.6~2.0

Extract from JIS B8210-2009 Spring Safety Valve for Steam and Gases

■ Allowed deviation of discharge-starting pressure

(1) For steam

There is no provision on the relief pressure of safety valve for steam.

(2) For gases

For valve for gases, the allowed deviation of start to discharge pressure is set pressure $\pm 5\%$ (minimum pressure: $\pm 0.025\text{MPa}$). In case of allowed deviation, which is not allowed to exceed set pressure, add the "+" side to "-" side.

Note: For valves for gases, the set pressure is generally the start to discharge pressure.

■ Allowed deviation of opening pressure (popping pressure)

(1) For steam

See Table 1 for the deviation of opening pressure. In case of allowed deviation, which is not allowed to exceed set pressure, add the "+" side to "-" side.

(2) For gases

For safety valves for gases, the allowed deviation of discharge-starting pressure is less than 1.1 times of start to discharge pressure. However, in the case of setting opening pressure, the deviation should be $\pm 3\%$ set pressure (minimum $\pm 0.015\text{MPa}$).

In case of allowed deviation, which is not allowed to exceed set pressure, add the "+" side to "-" side.

■ BLOWDOWN

(1) For steam

See Table 2 for the blowdown pressure of safety valves for steam. For valves for steam used with through flow boilers, re-heater, and piping, which opening pressure exceeds 0.3MPa , the blowdown pressure can be less than 10% of set pressure.

(2) For gases

See Table 3 for blowdown pressure of safety valves for gases.

Note: Unless otherwise specified in JIS B8210, Blowdown Standard of VENN shall apply.

■ Restriction of material use (pressure parts of safety valve) (Source: JIS B8210-2009)

(1) For steam

Material of pressure parts	Allowed range
Cast iron	Set pressure: Max. 1.6MPa . Fluid temperature: Max. 230°C
Ductile iron casting	Set pressure: Max. 2.4MPa . Fluid temperature: Max. 350°C

(2) For gases

Gas type	Toxic, flammable gases	Gases other than toxic, flammable gases	Toxic, flammable gases, other gases
	Allowed range		
Material of pressure parts			
Cast iron	Not allowed	Set pressure: Max.0.2 MPa	Not allowed
Ductile cast iron	Set pressure: Max.0.2 MPa	Set pressure: Max.1.6 MPa	Not allowed
Ductile iron casting	A: Application in system for highly toxic gases such as phosgene and hydrogen cyanide, etc is not allowed. B: For gases other than those mentioned in A, the set pressure should be Max.2.4 MPa. C: Fluid temperature should be higher than -5°C and lower than 350°C.		

TABLE1. TOLERANCE OF OPENING PRESSURE OF SAFETY VALVES FOR STEAM

(MPa)

Set pressure	Tolerance
Below 0.5	± 0.015
0.5 or more and less than 2.3	$\pm (3\% \text{ of set pressure})$
2.3 or more and less than 7.0	± 0.07
7.0 or more	$\pm (1\% \text{ of set pressure})$

*1. For steam, generally the set pressure is assumed to be the opening pressure.

*2. The tolerance of the opening pressure of the safety valves for steam used other than in boilers can be $\pm 3\%$ of the set pressure (minimum value $\pm 0.015\text{MPa}$).

TABLE2. BLOWDOWN PRESSURE OF SAFETY VALVES FOR STEAM

(MPa)

Set pressure	Blowdown
0.4 or less	0.03
Over 0.4	7%(4%) or less of set pressure

*1. Generally, the blowdown pressure for steam shall be the difference between the opening pressure and the reseating pressure.

*2. The figures in () can be determined in accordance with the agreement between the parties concerned.

TABLE3. BLOWDOWN PRESSURE OF SAFETY VALVES FOR GASES

(MPa)

Set pressure	Blowdown	
	Metal seat type	Soft seat type
0.2 or less	0.03 or less	0.05 or less
Over 0.2	15% or less of set pressure	25% or less of set pressure

*1. Generally, the blowdown pressure for gases shall be the difference between the start to discharge pressure and the reseating pressure. However, when set by the opening pressure, it shall be the difference between the opening pressure and the reseating pressure.

*2. The definition of the soft seated and metal seated types shall be in accordance with JIS B0100.

Note. Unless otherwise specified in JIS B8210, Blowdown Standard of VENN shall apply.

DATA/Safety Valves, Relief Valves

Applicable Laws & Regulations and Formulas for Calculating Relieving Capacity

Coefficients assigned to equations may be those specified in applicable laws/regulations or in-house data(※).

※In-house data

1. PRESSURE VESSEL CONSTRUCTION CODE (from JIS B8210-2009)

(1) For Steam

$$Q_m = 5.25 C' K_{dr}' A P$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

P: Absolute relieving pressure (MPa·A)

(Select the larger one of set pressure × 1.1 + 0.101 or set pressure + 0.020 + 0.101.)

C': Coefficient determined according to the property of steam
(See Tab.1 in Page 87.)

For saturated steam, see the following table:

Absolute relieving pressure (MPa·A)	C': Coefficient determined according to the property of steam
Max. 0.5	1*
over 0.5~1.0	0.98*
over 1.0~2.0	0.97*
over 2.0	0.96*

For superheated steam, See Tab.1. in Page 87.

K_{dr}': Relieving coefficient

Lift type: 0.864*

Full bore type: 0.777

(2) For Gases

$$Q_m = C'' K_{dr} P_1 A K_b \sqrt{\frac{M}{ZT}}$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

Z: Compression coefficient: 1* (See Fig.1 in Page 90)

T: Absolute temperature (K) of gases at relieving pressure

P₁: Relieving pressure (MPa·A)

(Select the larger one of set pressure × 1.1 + 0.101 or set pressure + 0.020 + 0.101.)

P₂: Back pressure (MPa·A)

C'': Coefficient determined according to κ (See Tab.5 in Page 88)

κ : Adiabatic exponent (Isentropic, See Tab.4 in Page 88).

The value will be 1.001 if it is not specified, in which case C''=23.95

K_{dr}': Relieving coefficient

Lift type: 0.864*

Full bore type: 0.777

K_b: Back pressure compensation coefficient (Depending on P₂/P₁ and κ .
See Tab.6 in Page 89)

M: Molecular weight of gas (See Tab.4 in Page 88)

■ Calculating maximum flow-in gas using the following formula:

$$G = 0.0028 v \rho d^2$$

G: Flow in gas (kg/h)

v : Velocity of gas (m/sec)

(More than 20 for saturated steam, or more than 30 for super-heated steam, or more than 10 for common gas)

ρ : Density of gas (kg/m³)

d : Internal diameter of pipe (mm)

(3) For water/hot water (also applicable for hot water with temperature higher than 120°C)

(1) In case of searching from relieving capacity:

$$S = \frac{W}{87.7 / ((P_1 + 0.1)^\kappa Y_1)}$$

(2) In case of searching from thermal input of pressure vessel or thermal output of hot water boiler:

$$S = \frac{Q_\varepsilon}{87.7 C / ((P_1 + 0.1)^\kappa Y_1)}$$

(If (P₁+0.1)^κ > (P₁-P₂) in formula (1) and (2), replace (P₁-P₂) with (P₁+0.1)^κ)S : Seat opening area (mm²)

W: Relieving capacity of valve (kg/h)

P₁: Relieving pressure (MPa) (See Note)

Lift type: set pressure × 1.1

For SL-37~40, 43, 44 type, see Page 65.

Full bore type: select the larger one of set pressure × 1.15 or set pressure + 0.034

Relief valve (type E · ED): select the larger one of set pressure × 1.25
or set pressure + 0.034P₂: Outlet pressure (MPa)

κ : Coefficient correction (See Fig.2 in Page 90)

Δt: Difference between the saturated temperature of relieving pressure P₁ and the temperature of hot water at inlet. (°C)Y₁: Density of the hot water at inlet (kg/L) (See Tab.2 in Page 87)

Q : Thermal input of pressure vessel or thermal output of hot water boiler (kJ/h)

ε : Coefficient of volumetrical expansion for water(1/°C) (See Tab.3 in Page 87)

C: Specific heat of water at constant pressure (kJ/kg°C) (See Tab.3 in Page 87)

Note: In the case of full-bore valve and relief valve, make sure the relieving pressure (P₁) does not exceed "maximum working pressure of pressure vessel or hot water boiler X 1.1" or "maximum working pressure + 0.034".

Applicable Laws & Regulations and Formulas for Calculating Relieving Capacity

Coefficients assigned to equations may be those specified in applicable laws/regulations or in-house data (※).

※ In-house data

2. BOILER CONSTRUCTION CODE (from JIS B8210-2009)

(1) For Steam

$$Q_m = 5.25 C' K_{dr} A P$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

 ℓ : Lift (mm)

d: Throat diameter (mm)

P: Absolute relieving pressure (MPa·A)

(Select the larger one of set pressure $\times 1.03 + 0.101$ or set pressure $+ 0.015 + 0.101$)

C': Coefficient determined according the property of steam (See Tab.1 in Page 87)

For saturated steam, see the following table:

Absolute relieving pressure (MPa·A)	C': Coefficient determined according the property of steam
Max. 0.5	1※
over 0.5~1.0	0.98※
over 1.0~2.0	0.97※
over 2.0	0.96※

For superheated steam, see Tab.1 in Page 87.

K_{dr}: Relieving coefficient

Lift type: 0.864※

Full bore type: 0.777

(2) For hot water (applicable when temperature is less than 120°C. If temperature is higher than 120 °C, then use the formula described in (1))

(1) In case of searching from relieving capacity:

$$S = \frac{W}{87.7 / (P_1 + 0.1) \kappa \gamma_1}$$

(2) In case of searching from thermal input of pressure vessel thermal output of hot water boiler:

$$S = \frac{Q_e}{87.7 C / (P_1 + 0.1) \kappa \gamma_1}$$

In formula (i) and (ii), if $(P_1 + 0.1) \kappa > (P_1 - P_2)$, then $(P_1 + 0.1) \kappa$ should be replaced by $(P_1 - P_2)$.S: Seat opening area (mm²)

W: Required relieving capacity of valve (kg/h)

Note: In the case of full-bore valve and relief valve, make sure the relieving pressure (P₁) does not exceed "maximum working pressure of pressure vessel or hot water boiler $\times 1.1$ " or "maximum working pressure $+ 0.034$ ".P₁: Relieving pressure (MPa) (see Note)Lift type: set pressure $\times 1.1$

For SL-37~40, 43, 44 type see Page 65.

Full bore type: select the larger one of set pressure $\times 1.15$ or set pressure $+ 0.034$ Relief valve (type E · ED): select the larger one of set pressure $\times 1.25$ or set pressure $+ 0.034$ P₂: Outlet pressure (MPa) κ : Coefficient correction (See Fig.2 in Page 90) Δt : Difference between the saturated temperature of relieving pressure P₁ and the temperature of hot water at inlet. (°C) γ_1 : Density of the hot water at inlet (kg/L) (See Tab.2 in Page 87)

Q : Thermal input of pressure vessel or thermal output of hot water boiler (kJ/h)

 ε : Coefficient of volumetrical expansion for water (1/°C) (See Tab.3 in Page 87)

C: Specific heat of water at constant pressure (kJ/kg°C) (See Tab.3 in Page 87)

NOTE

It is necessary installing safety valve when water temperature exceeds 120°C. The formula is as the following:

$$Q_m = 5.25 C' K_{dr} A P$$

In this case, the required relieving capacity (kg/h) of safety valve can be calculated using the following formula:

$$W = \frac{Q}{h_1 - h_2}$$

W: Required relieving capacity of safety valve (kg/h)

Q: Thermal output of hot water boiler (kJ/h)

h₁: Enthalpy of saturated steam that is equivalent to the maximum working pressure of boiler (kJ/kg).h₂: Enthalpy of water supply (kJ/kg)

$$W = \frac{Q_e}{C}$$

 ε : Coefficient of volumetrical expansion of water (1/°C) (See Tab.3 in Page 87)

C: Specific heat of water at constant pressure (kJ/kg°C) (See Tab.3 in Page 87)

(3) For dowerthm boiler

$$Q_m = C'' K_{dr} P_1 A K_b \sqrt{\frac{M}{ZT}}$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

 ℓ : Lift (mm)

d: Throat diameter (mm)

Z: Compression coefficient: 1※ (See Fig.1 in Page 90)

T: Absolute temperature (K) of gases at absolute relieving pressure

P₁: Absolute relieving pressure (MPa·A)(Select the larger one of set pressure $\times 1.1 + 0.101$ or set pressure $+ 0.020 + 0.101$)P₂: Absolute back pressure (MPa·A)C': Coefficient determined according to κ (See Tab.5, Page 88) κ : Adiabatic exponent (Isentropic, See Tab.4 in Page 88)

The value will be 1.001 if it is not specified, in which case C'=23.95

K_{dr}: Relieving coefficient

Lift type: 0.864※

Full bore type: 0.777

K_b: Back pressure compensation coefficient (Depending on P₂/P₁ and κ . See Tab.6 in Page 89)

M: Molecular weight of air (See Tab.4 in Page 88)

DATA/Safety Valves, Relief Valves

Applicable Laws & Regulations and Formulas for Calculating Relieving Capacity

Coefficients assigned to equations may be those specified in applicable laws/regulations or in-house data (※).

※In-house data

3. JIS B8210-2009: SPRING SAFETY VALVE FOR STEAM AND GAS

(1) For Steam

$$Q_m = 5.25 C' K_{d'} A P$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

P: Absolute relieving pressure (MPa·A)

Products for boiler: (Select the larger one of set pressure × 1.03 + 0.101

or set pressure + 0.015 + 0.101)

Products for pressure vessels: (Select the larger one of set pressure × 1.1 + 0.101

or set pressure + 0.020 + 0.101)

C': Coefficient determined according to the property of steam (See Tab.1 in Page 87.)

For saturated steam, see the following table:

Absolute flow rating pressure (MPa·A)	C': Coefficient depending on the nature of steam
Max. 0.5	1 [※]
Over 0.5~1.0	0.98 [※]
Over 1.0~2.0	0.97 [※]
Over 2.0	0.96 [※]

For superheated steam, See the table in Page 87.

K_{d'}: Relieving coefficientLift type: 0.864[※]

Full bore type: 0.777

(2) For Gases

$$Q_m = C'' K_{d'} P_1 A K_b \sqrt{\frac{M}{ZT}}$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

Z: Compression coefficient: 1[※] (See Fig. 1 in Page 90)

T: Absolute temperature (K) of gases at relieving pressure

P₁: Absolute relieving pressure (MPa·A)

(Select the larger one of set pressure × 1.1 + 0.101 or set pressure + 0.020 + 0.101)

P₂: Absolute back pressure (MPa·A)

C'': Coefficient determined according to κ (See Tab.5 in Page 88)

κ : adiabatic exponent (See Tab.4, Page 88)

The value will be 1.001 if it is not specified, in which case C''=23.95

K_{d'}: Relieving coefficientLift type: 0.864[※]

Full bore type: 0.777

K_b: Back pressure compensation coefficient (Depending on P₂/P₁ and κ . See Tab.6 in Page 89)

M: Molecular weight of air (See Tab.4 in Page 88)

4. ELECTRICITY BUSINESS ACT (Technical Standard for Thermal Equipments for Power Generation) (Formula source: JIS B8210-1994)

■ Applicable for boilers and supporting equipments

(1) For Steam

$$Q_m = 5.246 C K_{d'} A (P + 0.1) \times 0.9$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

P: Relieving pressure (MPa)

Set pressure ≤ 0.1 MPa: Set pressure + 0.02

Set pressure > 0.1 MPa: Set pressure × 1.03

C: Coefficient determined according to the property of steam (See Tab.1 in Page 87)

Set pressure is < 0.5 MPa·A, at saturated pressure: 1

Set pressure is ≥ 0.5 MPa·A, at saturated pressure: 0.98

Superheated steam: Please contact our agent in your area.

K_{d'}: Rated discharge coefficientLift type: 0.96[※]

Full bore type: 0.864

(2) For Gases

$$Q_m = C' K_{d'} A P_1 \sqrt{\frac{M}{ZT}} \times 0.9$$

Q_m: Relieving capacity (kg/h)A : Seat opening area (mm²)Lift type: $A = \pi D \ell$ Full bore type: $A = \frac{\pi d^2}{4}$

D: Seat opening diameter (mm)

ℓ: lift (mm)

d: throat diameter (mm)

Z: Compression coefficient: 1[※] (See Fig.1 in Page 90)

T: Absolute temperature (K) of gases at absolute relieving pressure

C': Coefficient determined according to κ and P₂/P₁ (See Fig.3 in Page 90)κ : Adiabatic exponent (C_p/C_v) (See Tab.4 in Page 88)

The value is considered as 1 if it is not clear.

P₂: Absolute back pressure (MPa·A)K_{d'}: Relieving coefficientLift type: 0.96[※]

Full bore type: 0.864

P₁: Absolute relieving pressure (MPa·A)

(Absolute value of "set pressure × 1.1")

M: Molecular weight of gas (See Tab.4 in Page 88)

DATA/Safety Valves, Relief Valves

Applicable Laws & Regulations and Formulas for Calculating Relieving Capacity

Coefficients assigned to equations may be those specified in applicable laws/regulations or in-house data (※).

※In-house data

5. IN-HOUSE STANDARDS (for liquids other than water and hot water)

$$W=161 \times AK \sqrt{PG}$$

W: Relieving capacity (kg/h)

A: Seat opening area (mm²)

Lift type: A=πDℓ

Full bore type: A=0.785d²

D: Seat opening diameter (mm)

ℓ: Lift (mm)

d: Throat diameter (mm)

G: Specific gravity upon the inlet side temperature

P: Relieving pressure (MPa)

K: Flow coefficient

Lift type: 0.55 for upper guide type

0.45 for blade type

Full bore type: 0.60

[The value may be different depending on type and accumulation]

TABLE1. COEFFICIENT ACCORDING TO PROPERTY OF STEAM C'

(JIS B8210-2009)

Absolute pressure (MPa)	Temp. (°C)	Saturated temperature	200	220	240	260	280	300	320	340	360	380	400	420	440	460
0.5		1.004	0.994	0.971	0.950	0.931	0.912	0.895	0.879	0.863	0.848	0.834	0.821	0.808	0.796	0.784
1.0		0.986	0.980	0.982	0.960	0.938	0.919	0.900	0.883	0.867	0.852	0.837	0.824	0.810	0.798	0.786
1.5		0.976	0.975	0.969	0.969	0.946	0.925	0.906	0.888	0.871	0.855	0.843	0.826	0.813	0.800	0.788
2.0		0.971		0.966	0.963	0.955	0.932	0.912	0.893	0.875	0.859	0.844	0.829	0.815	0.802	0.790
2.5		0.968			0.960	0.965	0.940	0.918	0.898	0.880	0.863	0.847	0.832	0.818	0.805	0.792
3.0		0.966			0.961	0.956	0.948	0.925	0.904	0.884	0.867	0.850	0.835	0.821	0.807	0.794
4.0		0.964				0.957	0.953	0.939	0.915	0.895	0.875	0.857	0.841	0.826	0.811	0.798
5.0		0.965					0.955	0.952	0.929	0.905	0.884	0.865	0.847	0.831	0.816	0.802
6.0		0.968					0.962	0.953	0.943	0.917	0.893	0.873	0.854	0.837	0.821	0.807
7.0		0.971						0.959	0.954	0.930	0.904	0.881	0.861	0.843	0.826	0.811
8.0		0.975						0.968	0.956	0.944	0.915	0.890	0.869	0.849	0.832	0.816
9.0		0.980							0.963	0.960	0.927	0.900	0.877	0.856	0.837	0.820
10.0		0.987								0.972	0.962	0.941	0.911	0.885	0.863	0.843
12.0		1.000									0.977	0.973	0.935	0.904	0.878	0.856
14.0		1.019										0.982	0.964	0.926	0.896	0.870
16.0		1.039										1.005	1.001	0.952	0.916	0.886
18.0		1.068										1.044	1.007	0.977	0.933	0.903
20.0		1.100											1.036	1.011	0.958	0.917

* When pressure/temperature is an intermediate value, it is necessary to take the minimum value of absolute pressure/temperature division and do not apply the proportional method. When absolute pressure is below 0.5 MPa·A, then 0.5 MPa·A should be used as absolute pressure. For example, when relieving pressure (absolute pressure) is 1.6 MPa·A and temperature is 245°C, C' = 0.946.

TABLE2. HOT WATER SPECIFIC GRAVITY γ_t(kg/L)

(Source: Interpretation of Boiler Structure Standard)

Pressure MPa·A	0.1	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	2.2	2.5
40	0.992	0.992	0.992	0.993	0.993	0.993	0.993	0.993	0.993	0.993	0.993	0.993	0.993
50	0.998	0.988	0.988	0.988	0.988	0.988	0.989	0.989	0.989	0.989	0.989	0.989	0.989
60	0.983	0.983	0.983	0.983	0.983	0.984	0.984	0.984	0.984	0.984	0.984	0.984	0.984
70	0.978	0.978	0.978	0.978	0.978	0.978	0.978	0.978	0.978	0.978	0.979	0.979	0.979
80	0.972	0.972	0.972	0.972	0.972	0.972	0.972	0.972	0.972	0.972	0.973	0.973	0.973
90	0.965	0.965	0.965	0.965	0.965	0.966	0.966	0.966	0.966	0.966	0.966	0.966	0.966
100		0.958	0.958	0.958	0.958	0.959	0.959	0.959	0.959	0.959	0.959	0.959	0.959
110		0.951	0.951	0.951	0.951	0.951	0.951	0.951	0.951	0.951	0.952	0.952	0.952
120		0.943	0.943	0.943	0.943	0.943	0.943	0.943	0.944	0.944	0.944	0.944	0.944
130			0.935	0.935	0.935	0.935	0.935	0.935	0.935	0.935	0.935	0.936	0.936
140			0.926	0.926	0.926	0.926	0.926	0.926	0.927	0.927	0.927	0.927	0.927
150				0.917	0.917	0.917	0.917	0.917	0.917	0.918	0.918	0.918	0.918
160					0.907	0.908	0.908	0.908	0.908	0.908	0.908	0.908	0.908
170					0.897	0.897	0.898	0.898	0.898	0.898	0.898	0.898	0.898
180							0.887	0.887	0.887	0.887	0.888	0.888	0.888
190							0.876	0.876	0.876	0.877	0.877	0.877	0.877
200								0.865	0.865	0.865	0.865	0.865	0.865
210										0.853	0.853	0.853	0.853
220													0.841

Note: Intermediate value should be calculated using the proportional method.

* Water density should be "1" when temperature is lower than 40°C.

TABLE3. SPECIFIC HEAT AND EXPANSION COEFFICIENT OF HOT WATER

(Source: Interpretation of Boiler Structure Standard)

Temp. °C	Specific heat of water at constant pressure C _p kJ/kg°C	Expansion coefficient ε 1/°C
Below 40°C	4.150	0.00039
40	4.179	0.00039
50	4.181	0.00046
60	4.185	0.00053
70	4.190	0.00060
80	4.197	0.00066
90	4.205	0.00072
100	4.216	0.00079
110	4.229	0.00085
120	4.245	0.00090
130	4.263	0.00097
140	4.285	0.00103
150	4.310	0.00110
160	4.339	0.00118
170	4.371	0.00126
180	4.408	0.00134
190	4.449	0.00145
200	4.497	0.00155
210	4.551	0.00165
220	4.613	0.00179

Note: Intermediate value should be calculated using the proportional method.

DATA/Safety Valves, Relief Valves

Applicable Laws & Regulations and Formulas for Calculating Relieving Capacity

TABLE4. GAS PROPERTY

(JIS B8210-2009)

Gas names	Chemical symbol	Molecular weight M (kg/kmol)	Adiabatic (isentropic) index κ (1.013bar a, 15°C)	Critical pressure Pc (bar a.)	Critical temp. Tc (K)	Critical pressure ratio
Acetylene	C ₂ H ₂	26.02	1.26	62.82	309.15	0.553
Air	—	28.96	1.40	37.69	132.45	0.528
Ammonia	NH ₃	17.03	1.31	112.98	405.55	0.544
Argon	Ar	39.91	1.66	48.64	151.15	0.488
Normal butane	C ₄ H ₁₀	58.08	1.11	36.48	426.15	0.583
Carbon dioxide	CO ₂	44.00	1.30	73.97	304.25	0.546
Carbon monoxide	CO	28.00	1.40	35.46	134.15	0.528
Chlorine	Cl ₂	70.91	1.35	77.11	417.15	0.537
Chlorofluoromethane	CHClF ₂	86.47	1.18	49.14	370.15	0.568
Ethane	C ₂ H ₆	30.05	1.22	49.45	305.25	0.561
Ethylene	C ₂ H ₄	28.03	1.25	51.57	282.85	0.555
Hydrogen	H ₂	2.015	1.41	12.97	33.25	0.527
Hydrogen chloride	HCl	36.46	1.41	82.68	324.55	0.527
Hydrogen sulfide	H ₂ S	34.08	1.32	90.08	373.55	0.542
Isobutane	CH(CH ₃) ₂	58.08	1.11	37.49	407.15	0.583
Methane	CH ₄	16.03	1.31	46.41	190.65	0.544
Methyl chloride	CH ₃ Cl	50.48	1.28	66.47	416.25	0.549
Nitrogen	N ₂	28.02	1.40	33.94	126.05	0.528
Nitrogen suboxide	N ₂ O	44.02	1.30	72.65	309.65	0.546
Oxygen	O ₂	32.00	1.40	50.36	154.35	0.528
Propane	C ₃ H ₈	44.06	1.13	43.57	368.75	0.579
Propylene	C ₃ H ₆	42.05	1.15	46.60	365.45	0.574
Sulfur dioxide	SO ₂	64.07	1.29	78.73	430.35	0.548

TABLE5. COEFFICIENT DEPENDING ON ADIABATIC (ISENTROPIC) EXPONENT (κ) (C") (JIS B8210-2009)

κ	C"	κ	C"	κ	C"	κ	C"	κ	C"	κ	C"
0.41	16.65	0.71	20.96	1.01	24.04	1.31	26.41	1.61	28.34	1.91	29.96
0.42	16.82	0.72	21.08	1.02	24.12	1.32	26.49	1.62	28.40	1.92	30.01
0.43	17.00	0.73	21.20	1.03	24.21	1.33	26.56	1.63	28.46	1.93	30.06
0.44	17.17	0.74	21.31	1.04	24.30	1.34	26.63	1.64	28.52	1.94	30.10
0.45	17.33	0.75	21.43	1.05	24.39	1.35	26.69	1.65	28.58	1.95	30.15
0.46	17.50	0.76	21.54	1.06	24.47	1.36	26.76	1.66	28.63	1.96	30.20
0.47	17.66	0.77	21.65	1.07	24.56	1.37	26.83	1.67	28.69	1.97	30.25
0.48	17.82	0.78	21.76	1.08	24.64	1.38	26.90	1.68	28.74	1.98	30.30
0.49	17.98	0.79	21.87	1.09	24.72	1.39	26.97	1.69	28.80	1.99	30.34
0.50	18.13	0.80	21.98	1.10	24.81	1.40	27.03	1.70	28.86	2.00	30.39
0.51	18.29	0.81	22.09	1.11	24.89	1.41	27.10	1.71	28.91	2.01	30.44
0.52	18.44	0.82	22.19	1.12	24.97	1.42	27.17	1.72	28.97	2.02	30.49
0.53	18.58	0.83	22.30	1.13	25.05	1.43	27.23	1.73	29.02	2.03	30.53
0.54	18.73	0.84	22.40	1.14	25.13	1.44	27.30	1.74	29.08	2.04	30.58
0.55	18.88	0.85	22.51	1.15	25.21	1.45	27.36	1.75	29.13	2.05	30.63
0.56	19.02	0.86	22.61	1.16	25.29	1.46	27.43	1.76	29.18	2.06	30.67
0.57	19.16	0.87	22.71	1.17	25.37	1.47	27.49	1.77	29.24	2.07	30.72
0.58	19.30	0.88	22.81	1.18	25.45	1.48	27.55	1.78	29.29	2.08	30.76
0.59	19.44	0.89	22.91	1.19	25.53	1.49	27.62	1.79	29.34	2.09	30.81
0.60	19.57	0.90	23.01	1.20	25.60	1.50	27.68	1.80	29.40	2.10	30.85
0.61	19.71	0.91	23.11	1.21	25.68	1.51	27.74	1.81	29.45	2.11	30.90
0.62	19.84	0.92	23.20	1.22	25.76	1.52	27.80	1.82	29.50	2.12	30.94
0.63	19.97	0.93	23.30	1.23	25.83	1.53	27.86	1.83	29.55	2.13	30.99
0.64	20.10	0.94	23.39	1.24	25.91	1.54	27.93	1.84	29.60	2.14	31.03
0.65	20.23	0.95	23.49	1.25	25.98	1.55	27.99	1.85	29.65	2.15	31.07
0.66	20.35	0.96	23.58	1.26	26.05	1.56	28.05	1.86	29.71	2.16	31.12
0.67	20.48	0.97	23.67	1.27	26.13	1.57	28.11	1.87	29.76	2.17	31.16
0.68	20.60	0.98	23.76	1.28	26.20	1.58	28.17	1.88	29.81	2.18	31.21
0.69	20.72	0.99	23.86	1.29	26.27	1.59	28.23	1.89	29.86	2.19	31.25
0.70	20.84	1.001	23.95	1.30	26.34	1.60	28.29	1.90	29.91	2.20	31.29

Note: Intermediate value should be calculated using the interpolational method.

Calculation formula

$$C = 39.48 \sqrt{\kappa \left(\frac{2}{\kappa + 1} \right)^{\frac{\kappa + 1}{\kappa - 1}}}$$

DATA/Safety Valves, Relief Valves

Fig.1 Coefficient of compressibility Z (JIS B8210-2009)




Fig.2 $\Delta t^\circ\text{C}$ correction coefficient κ





Fig.3 Coefficient (C') based on κ and P_2/P_1 (JIS B8210-2009)



Key Points for Installation of Safety Valves and Relief Valves

1. Installation

- ❶ Safety valve should be vertical to pipe. Before installation, remove scale and dust and clean the surfaces that contact with gasket.
- ❷ The diameter of the installation pipe should be larger than the diameter of valve. To reduce pressure loss to minimum degree, the stand pipe should be as short as possible.
- ❸ The stand pipe should be rigid and hard enough to bear the compression force, shearing force, bending stress or other counterforce caused by relieving of safety valve.
- ❹ Compared with the diameter of the outlet of safety valve, the diameter of the discharge pipe should be as large as possible. The discharge pipe should be as short as possible, without any bending, lead to outside of the door or other safe place, and be properly supported to avoid the occurrence of undesired stress (including thermal stress).


When deciding the place that the outlet of the discharge pipe faces, pay attention to the following issues.

- To avoid installation place where is influenced by explosive sound and blast.
- Avoid damage to electrical equipments, machines, tools etc. in the case the fluid is steam or water.
- Avoid corrosion, poisoning, anoxia etc. in the case the fluid is harmful gas.

- ❺ In the case of screwed type safety valve or relief valve, install union joint at the discharge pipe of the outlet side to allow easy dismounting (see Fig.1 in next page).
- ❻ At parts of the discharge pipe where drain or rain may accumulate, install the drain outlet, which is possible to discharge drain completely, and connect to dike.
- ❼ In the case of full bore type safety valve for liquids or harmful gases and have faucet for adjusting back pressure, install the valve on the outlet discharge pipe (see Fig.3 in next page).

- ❽ To avoid adverse impact on safety valve that is caused by thermal expansion of devices or discharge pipe, install proper expansion joint at the outlet of valve and install a discharge pipe at the end (see the figure below). To limit counterforce, the distance between the axes of the valve and the center of discharge pipe should be as short as possible, and the radius of the elbow pipe should be at least 2D (D: the internal diameter of the elbow). below figure also shows the standard dimensions of the discharge pipe of safety valve.

- ❾ Cares should be paid on installation of valves with lever (open type). It may effuse fluid from upper cap when such valves are operating (see Fig.5 in the next page).



REFERENCE DIMENSION FOR EXHAUST PIPE

(mm)

Outlet size	D	d	(A)	B	C	E	L	H	N
40(1½")	40	65	130	60	80	30	130	220	Rc¾"
50(2")	50	80	150	60	90	40	150	230	Rc½"
65(2½")	65	100	200	60	100	40	180	270	Rc½"
80(3")	80	125	200	70	120	50	200	310	Rc½"
100(4")	100	150	250	70	140	60	250	370	Rc¾"
125(5")	125	200	300	80	160	70	300	430	Rc1"
150(6")	150	200	300	80	180	70	350	500	Rc1"
200(8")	200	250	380	100	220	80	450	610	Rc1"

2. Maintenance and operating instructions

- ❶ At the installation of safety valves avoid the place where there is possibility to obstruct their functions by vibration or corrosion and do not give impact from outside.
- ❷ After installation, make sure the pressure of the device has reached at least 75% discharge pressure of the valve before using the test lever to start the valve.
- ❸ Normal working pressure of the equipment shall not exceed 90% of the blowdown pressure of the valve and 80 to 85% when pulsation is expected.

- ❹ If possible, remove safety valve before making water pressure test. To make water pressure test without removing safety valve, pay attention to the following below (see Fig.4 in the next page).
 - Ⓐ To prevent valve from being damaged due to improper load, when the pressure of the device reaches 80~90% of discharge pressure, install test gag* and press lightly on the end of valve shaft. The test gag must be rotated using hand. If you rotate it using

spanner or other tools, there may have excessively large pressing force, the seat may be damaged, the shaft may be bent, and the valve may not function normally.

- Ⓑ After water pressure test and the pressure reduces to 80~90% relieving pressure, remove test gag immediately.

※ The test gag is optional item.

Key Points for Installation of Safety Valves and Relief Valves

PIPING EXAMPLE

Fig.1 Example: Pressure tank installation




Fig.2 Example: Installation of the secondary side of pressure reducing valve




Fig.3 Example connection of back pressure adjusting cock




Fig.4 Installation of test gag







Fig.5 Lever structure

Lever structure of SL-37, 39, 39F,43 Type
For air, gas, or liquid



Open type lever structure



■ FULL BORE TYPE

Qm=5.25C'Kdr'AP

$$\left\{ \begin{array}{l} C'=1 \text{ (when } P \leq 0.5 \text{ MPa} \cdot \text{A) or } 0.98 \text{ (when } P \text{ is over } 0.5 \sim 1.0 \text{ MPa} \cdot \text{A) or } 0.97 \text{ (when } P \text{ is over } 1.0 \sim 2.0 \text{ MPa} \cdot \text{A) or } 0.96 \text{ (when } P > 2.0 \text{ MPa} \cdot \text{A)} \\ Kdr'=0.777, P \text{ (MPa} \cdot \text{A): the larger one of (set pressure} \times 1.1 + 0.101) \text{ or (set pressure} + 0.02 + 0.101). \end{array} \right\}$$

(kg/h)

Model name	Size (mm)	dt	Set pressure MPa	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
SF-1H, 2H	20	15	176.6	159	231	310	381	459	537	614	692	762	839	916	992	1060	1140	1220	1300	1370	1430	1510	1590										
	25	19	283.3	255	370	498	612	737	861	986	1110	1220	1340	1460	1590	1710	1830	1960	2080	2200	2300	2430	2550										
	40	30	706.5	636	925	1240	1520	1830	2140	2460	2770	3040	3350	3660	3970	4270	4580	4890	5200	5500	5750	6060	6360										
	50	38	1133.5	1020	1480	1990	2450	2940	3440	3940	4440	4890	5380	5870	6370	6860	7360	7850	8340	8840	9230	9720	10200										
SF-19L, 20L	15	11	94.9	85.5	124	166	205	246	288	330	372	409	450	492	533	574	616	657	698	740	773	814	855	896	936	977	1010	1050	1100	1140	1180	1220	1260
	20	15	176.6	159	231	310	381	459	537	614	692	762	839	916	992	1060	1140	1220	1300	1370	1430	1510	1590	1660	1740	1810	1890	1970	2040	2120	2190	2270	2350
	25	19	283.3	255	370	498	612	737	861	986	1110	1220	1340	1460	1590	1710	1830	1960	2080	2200	2300	2430	2550	2670	2790	2910	3040	3160	3280	3400	3520	3650	3770
SF-13L, 14L	25	19	283.3	255	370	498	612	737	861	986	1110	1220	1340																				
SF-13L	40	25	490.6	442	642	862	1060	1270	1490	1700	1920	2110	2330	2540	2750	2970	3180	3390	3610	3820	3990	4200	4420	4630	4840	5050	5260	5470	5680	5900	6110	6320	6530
	30	34	706.5	636	925	1240	1520	1830	2140	2460	2770	3040	3350	3660	3970	4270	4580	4890	5200	5500	5750	6060	6360	6670	6970	7270	7580	7880	8190	8490	8800	9100	9400
	50	34	907.4	818	1180	1590	1960	2360	2760	3150	3550	3910	4310	4700	5100	5490	5890	6280	6680	7070	7390	7780	8170	8560	8950	9340	9740	10100	10500	10900	11300	11600	12000
	38	38	1133.5	1020	1480	1990	2450	2940	3440	3940	4440	4890	5380	5870	6370	6860	7360	7850	8340	8840	9230	9720	10200	10700	11100	11600	12100	12600	13100	13600	14100	14600	15000
SF-16L (0.1~1MPa)	65	43	1451.4	1300	1900	2550	3130	3770	4410	5050	5690	6260	6890	7520	8160	8790	9420	10000	10600	11300	11800	12400	13000	13700	14300	14900	15500	16200	16800	17400	18000	18700	19300
	49	49	1884.7	1690	2460	3310	4070	4900	5730	6560	7390	8130	8950	9770	10500	11400	12200	13000	13800	14600	15300	16100	16900	17700	18600	19400	20200	21000	21800	22600	23400	24200	25100
SF-17L SF-18L (1~2MPa)	80	55	2374.6	2140	3100	4170	5130	6170	7220	8260	9310	10200	11200	12300	13300	14300	15400	16400	17400	18500	19300	20300	21300	22400	23400	24400	25400	26500	27500	28500	29500	30600	31600
	69	61	2920.9	2630	3820	5130	6310	7600	8880	10100	11400	12600	13800	15100	16400	17600	18900	20200	21500	22700	23800	25000	26300	27500	28800	30000	31300	32600	33800	35100	36300	37600	38900
SF-19L SF-20L (2~3MPa)	100	69	3737.3	3360	4890	6570	8080	9720	11300	13000	14600	16100	17700	19300	21000	22600	24200	25800	27500	29100	30400	32000	33600	35200	36800	38500	40100	41700	43300	44900	46500	48100	49700
	76	76	4534.1	4080	5930	7970	9800	11700	13700	15700	17700	19500	21500	23500	25400	27400	29400	31400	33300	35300	36900	38900	40800	42800	44700	46700	48600	50600	52500	54500	56400	58400	60300
	125	86	5805.8	5230	7600	10200	12500	15100	17600	20200	22700	25000	27500	30100	32600	35100	37600	40200	42700	45200	47300	49800	52300	54800	57300	59800	62300	64800	67300	69800	72300	74800	77300
	95	95	7084.6	6380	9270	12400	15300	18400	21500	24600	27700	30500	33600	36700	39800	42900	46000	49000	52100	55200	57700	60700	63800	66800	69900	72900	76000	79000	82100	85200	88200	91300	94300
	150	105	8654.6	7800	11300	15200	18700	22500	26300	30100	33900	37300	41100	44800	48600	52400	56100	59900	63700	67400	70500	74200	77900	81700	85400	89100	92800	96600	100000	104000	107000	111000	115000
	115	115	10381.6	9350	13500	18200	22400	27000	31500	36100	40700	44800	49300	53800	58300	62800	67400	71900	76400	80900	84600	89000	93500	98000	102000	106000	111000	115000	120000	124000	129000	133000	138000

dt: Throat dia. (mm), A: Seat opening area (mm²)

■ LIFT TYPE

Qm=5.25C'Kdr'AP

$$\left\{ \begin{array}{l} C'=1 \text{ (when } P \leq 0.5 \text{ MPa} \cdot \text{A) or } 0.98 \text{ (when } P \text{ is over } 0.5 \sim 1.0 \text{ MPa} \cdot \text{A) or } 0.97 \text{ (when } P \text{ is over } 1.0 \sim 2.0 \text{ MPa} \cdot \text{A) or } 0.96 \text{ (when } P > 2.0 \text{ MPa} \cdot \text{A)} \\ Kdr'=0.864, P \text{ (MPa} \cdot \text{A): the larger one of (set pressure} \times 1.1 + 0.101) \text{ or (set pressure} + 0.02 + 0.101). \end{array} \right\}$$

(kg/h)

Size (mm)	D	Set pressure MPa	0.05	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
15	15	18.8	14.5	18.8	27.3	36.7	45.2	54.4	63.5	72.7	81.9	90.2	99.3	108	117	126	135	144	153	163	170	179	188	197	206	215	224	233	242	251	260	269	278
20	20	31.4	24.3	31.4	45.7	61.3	75.5	90.8	106	121	136	150	165	181	196	211	226	241	257	272	284	299	314	329	344	359	374	389	404	419	434	449	465
25	25	54.9	42.5	55	79.9	107	132	158	185	212	239	263	290	316	343	369	396	422	449	476	497	523	550	576	602	628	655	681	707	734	760	786	813
32	32	80.3	62.2	80.4	116	156	193	232	271	310	350	385	424	463	502	540	579	618	657	696	727	766	804	843	881	919	958	996	1030	1070	1110	1150	1180
40	40	125.6	97.4	125	182	245	302	363	424	486	547	602	663	724	785	846	906	967	1020	1080	1130	1190	1250	1310	1370	1430	1490	1550	1610	1670	1730	1790	1860
50	50	204.1	158	204	297	399	490	590	690	790	890	979	1070	1170	1270	1370	1470	1570	1670	1770	1840	1940	2040	2140	2240	2330	2430	2530	2630	2720	2820	2920	3020
65	65	346.9	269	347	505	678	834	1000	1170	1340	1510	1660	1830	2000	2160	2330	2500	2670	2840	3000	3140	3300	3470	3640	3800	3970	4140	4300	4470	4630	4800	4970	5130
75	75	447.4	347	448	651	874	1070	1290	1510	1730	1950	2140	2360	2580	2790	3010	3230	3440	3660	3870	4050	4260	4480	4690	4910	5120	5340	5550	5760	5980	6190	6410	6620
80	78.4	492.3	381	493	716	962	1180	1420	1660	1900	2140	2360	2600																				
100	100	785.0	608	786	1140	1530	1880	2270	2650	3030	3420	3760	4140	4520	4900	5280	5660	6040	6420	6800	7110	7480	7860	8240	8610	8990	9360	9740	10100	10400	10800	11200	11600
	99.4	780.2	605	782	1130	1520	1870	2250	2630	3020	3400	3740	4120																				
125	125	1256.0	974	1250	1820	2450	3020	3630	4240	4860	5470	6020	6630	7240	7850	8460	9060	9670	10200	10800	11300	11900	12500	13100	13700	14300	14900	15500	16100	16700	17300	17900	18600
	130	1347.0	1040	1350	1960	2630	3230	3890	4550	5210	5870	6460	7110																				
150	150	1789.8	1380	1790	2600	3490	4300	5170	6050	6920	7800	8590	9450	10300	11100	12000	12900	13700	14600	15500	16200	17000	17900	18700	19600	20500	21300	22200	23000	23900	24700	25600	26500

■ FULL BORE TYPE

$$Q_m = C'' K_{ar} P_1 A K_b \sqrt{\frac{M}{ZT}} \dots \left\{ \begin{array}{l} C'' = 27.03, K_{ar} = 0.777, M = 28.96, Z = 1, T = 293 \\ P_1 = \text{the larger one of (set pressure} \times 1.1 + 0.101) \text{ or (set pressure} + 0.02 + 0.101) \end{array} \right\}$$

Model name	Size (mm)	dt (mm)	Set pressure MPa	A	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
SF-1H, 2H	20	15	176.6		257	374	502	630	759	887	1010	1140	1270	1400	1520	1650	1780	1910	2040	2170	2290	2420	2550	2680										
	25	19	283.3		413	600	806	1010	1210	1420	1620	1830	2040	2240	2450	2650	2860	3060	3270	3480	3680	3890	4090	4300										
	40	30	706.5		1030	1490	2010	2520	3030	3550	4060	4570	5080	5600	6110	6620	7140	7650	8160	8680	9190	9700	10200	10700										
	50	38	1133.5		1650	2400	3220	4040	4870	5690	6510	7340	8160	8980	9810	10600	11400	12200	13100	13900	14700	15500	16300	17200										
SF-19L, 20L	15	11	94.9		138	201	270	338	407	476	545	614	683	752	821	890	959	1020	1090	1160	1230	1300	1370	1440	1510	1570	1640	1710	1780	1850	1920	1990	2060	2130
	20	15	176.6		257	374	502	630	759	887	1010	1140	1270	1400	1520	1650	1780	1910	2040	2170	2290	2420	2550	2680	2810	2930	3060	3190	3320	3450	3580	3700	3830	3960
	25	19	283.3		413	600	806	1010	1210	1420	1620	1830	2040	2240	2450	2650	2860	3060	3270	3480	3680	3890	4090	4300	4500	4710	4920	5120	5330	5530	5740	5950	6150	6360
SF-13L, 14L	25	19	283.3		413	600	806	1010	1210	1420	1620	1830	2040	2240																				
SF-13L	40	25	490.6		715	1030	1390	1750	2100	2460	2820	3170	3530	3890	4240	4600	4950	5310	5670	6020	6380	6740	7090	7450	7810	8160	8520	8870	9230	9590	9940	10300	10600	11000
	30		706.5		1030	1490	2010	2520	3030	3550	4060	4570	5080	5600	6110	6620	7140	7650	8160	8680	9190	9700	10200	10700	11200	11700	12200	12700	13200	13800	14300	14800	15300	15800
	50	34	907.4		1320	1920	2580	3240	3900	4550	5210	5870	6530	7190	7850	8510	9170	9830	10400	11100	11800	12400	13100	13700	14400	15100	15700	16400	17000	17700	18300	19000	19700	20300
	38		1133.5		1650	2400	3220	4040	4870	5690	6510	7340	8160	8980	9810	10600	11400	12200	13100	13900	14700	15500	16300	17200	18000	18800	19600	20500	21300	22100	22900	23800	24600	25400
SF-16L (0.1~1MPa)	65	43	1451.4		2110	3070	4130	5180	6230	7290	8340	9400	10400	11500	12500	13600	14600	15700	16700	17800	18800	19900	20900	22000	23100	24100	25200	26200	27300	28300	29400	30400	31500	32500
	49		1884.7		2750	3990	5360	6730	8100	9470	10800	12200	13500	14900	16300	17600	19000	20400	21700	23100	24500	25800	27200	28600	30000	31300	32700	34100	35400	36800	38200	39500	40900	42300
SF-17L SF-18L (1~2MPa)	80	55	2374.6		3460	5030	6750	8480	10200	11900	13600	15300	17100	18800	20500	22200	24000	25700	27400	29100	30900	32600	34300	36000	37800	39500	41200	42900	44700	46400	48100	49800	51600	53300
	61		2920.9		4260	6190	8310	10400	12500	14600	16700	18900	21000	23100	25200	27400	29500	31600	33700	35800	38000	40100	42200	44300	46400	48600	50700	52800	54900	57100	59200	61300	63400	65500
SF-19L SF-20L (2~3MPa)	100	69	3737.3		5450	7920	10600	13300	16000	18700	21400	24200	26900	29600	32300	35000	37700	40400	43200	45900	48600	51300	54000	56700	59400	62200	64900	67600	70300	73000	75700	78400	81200	83900
	76		4534.1		6610	9610	12900	16100	19400	22700	26000	29300	32600	35900	39200	42500	45800	49100	52400	55700	59000	62300	65500	68800	72100	75400	78700	82000	85300	88600	91900	95200	98500	101000
	125	86	5805.8		8470	12300	16500	20700	24900	29100	33300	37600	41800	46000	50200	54400	58600	62900	67100	71300	75500	79700	83900	88200	92400	96600	100800	105000	109000	113000	117000	121000	126000	130000
	95		7084.6		10300	15000	20100	25300	30400	35500	40700	45800	51000	56100	61300	66400	71600	76700	81900	87000	92200	97300	102000	107000	112000	117000	123000	128000	133000	138000	143000	148000	153000	159000
	150	105	8654.6		12600	18300	24600	30900	37200	43400	49700	56000	62300	68600	74900	81200	87400	93700	100000	106000	112000	118000	125000	131000	137000	144000	150000	156000	162000	169000	175000	181000	188000	194000
	115		10381.6		15100	22000	29500	37000	44600	52100	59700	67200	74700	82300	89800	97400	104000	112000	120000	127000	135000	142000	150000	157000	165000	172000	180000	187000	195000	202000	210000	218000	225000	233000

dt: Throat dia. (mm), A: Seat opening area (mm²)

■ LIFT TYPE

$$Q_m = C'' K_{ar} P_1 A K_b \sqrt{\frac{M}{ZT}} \dots \left\{ \begin{array}{l} C'' = 27.03, K_{ar} = 0.864, M = 28.96, Z = 1, T = 293 \\ P_1 = \text{the larger one of (set pressure} \times 1.1 + 0.101) \text{ or (set pressure} + 0.02 + 0.101) \end{array} \right\}$$

Size (mm)	D	Set pressure MPa	A																															
				0.05	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
15	15	18.8		23.3	30.5	44.3	59.4	74.6	89.8	105	120	135	150	165	180	196	211	226	241	256	272	287	302	317	332	347	363	378	393	408	423	439	454	469
20	20	31.4		39	50.9	74	99.3	124	150	175	200	226	251	276	302	327	352	378	403	429	454	479	505	530	555	581	606	631	657	682	708	733	758	784
25	25	54.9		68.2	89	129	173	218	262	306	351	395	439	484	528	572	617	661	705	750	794	838	883	927	971	1010	1060	1100	1140	1190	1230	1280	1320	1370
32	32	80.3		99.8	130	189	254	318	383	448	513	578	643	708	772	837	902	967	1030	1090	1160	1220	1290	1350	1420	1480	1550	1610	1680	1740	1810	1870	1940	2000
40	40	125.6		156	203	296	397	498	600	701	803	904	1000	1100	1200	1310	1410	1510	1610	1710	1810	1910	2020	2120	2220	2320	2420	2520	2620	2730	2830	2930	3030	3130
50	50	204.1		253	331	481	645	810	975	1140	1300	1470	1630	1790	1960	2120	2290	2450	2620	2780	2950	3110	3280	3440	3610	3770	3940	4100	4270	4430	4600	4760	4930	5090
65	65	346.9		431	562	817	1090	1370	1650	1930	2210	2490	2770	3050	3330	3610	3890	4170	4450	4730	5020	5300	5580	5860	6140	6420	6700	6980	7260	7540	7820	8100	8380	8660
75	75	447.4		556	725	1050	1410	1770	2130	2490	2860	3220	3580	3940	4300	4660	5020	5390	5750	6110	6470	6830	7190	7550	7910	8280	8640	9000	9360	9720	10000	10400	10800	11100
80	78.4	492.3		611	798	1160	1550	1950	2350	2750	3140	3540	3940	4340																				
100	100	785.0		975	1270	1850	2480	3110	3750	4380	5020	5650	6280	6920	7550	8190	8820	9450	10000	10700	11300	11900	12600	13200	13800	14500	15100	15700	16400	17000	17700	18300	18900	19600
	99.4	780.2		969	1260	1830	2460	3090	3720	4350	4980	5610	6240	6870																				
125	125	1256.0		1560	2030	2960	3970	4980	6000	7010	8030	9040	10000	11000	12000	13100	14100	15100	16100	17100	18100	19100	20200	21200	22200	23200	24200	25200	26200	27300	28300	29300	30300	31300
	130	1347.0		1670	2180	3170	4260	5350	6430	7520	8610	9700	10700	11800																				
150	150	1789.8		2220	2900	4210	5660	7100	8550	10000	11400	12800	14300	15700	17200	18600	20100	21500	23000	24400	25900	27300	28700	30200	31600	33100	34500	36000	37400	38900	40300	41800	43200	44600
	160	2009.6		2490	3260	4730	6350	7980	9600	11200	12800	14400	16000	17700																				

■ FULL BORE TYPE

$$W=161 \times AK\sqrt{PG} \quad (K=0.6, G=1, \text{Accumulation } 15\% \text{ } A=0.785dt^2)$$

(10³kg/h)

	Size mm	Set pressure MPa	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
SF-20	15	11	3.10	4.39	5.38	6.21	6.95	7.61	8.22	8.79	9.32	9.83	10.3	10.7	11.2	11.6	12.0	12.4	12.8	13.1	13.5	13.9	14.2	14.5	14.9	15.2	15.5	15.8	16.1	16.4	16.7	17.0
	20	15	5.78	8.18	10.0	11.5	12.9	14.1	15.3	16.3	17.3	18.2	19.1	20.0	20.8	21.6	22.4	23.1	23.8	24.5	25.2	25.8	26.5	27.1	27.7	28.3	28.9	29.4	30.3	30.6	31.1	31.6
	25	19	9.28	13.1	16.0	18.5	20.7	22.7	24.5	26.2	27.8	29.3	30.7	32.1	33.4	34.7	35.9	37.1	38.2	39.3	40.4	41.5	42.5	43.5	44.5	45.4	46.4	47.3	48.2	49.1	49.9	50.8
SF-14	25	19	9.28	13.1	16.0	18.5	20.7	22.7	24.5	26.2	27.8	29.3																				
SF-14 SF-16 (0.1~1MPa)	40	25	16.0	22.7	27.8	32.1	35.9	39.3	42.5	45.4	48.2	50.8	53.3	55.6	57.9	60.1	62.2	64.2	66.2	68.1	70.0	71.8	73.6	75.3	77.0	78.7	80.3	81.9	83.5	85.0	86.5	88.0
		30	23.1	32.7	40.0	46.2	51.7	56.6	61.2	65.4	69.4	73.1	76.7	80.1	83.4	86.5	89.6	92.5	95.4	98.1	100	103	106	108	110	113	115	118	120	122	124	126
	50	34	29.7	42.0	51.4	59.4	66.4	72.8	78.6	84.0	89.1	93.9	98.5	102	107	111	115	118	122	126	129	132	136	139	142	145	148	151	154	157	160	162
		38	37.1	52.5	64.3	74.2	83.0	90.9	98.2	105	111	117	123	128	133	138	143	148	153	157	161	166	170	174	178	181	185	189	192	196	199	203
	65	43	47.5	67.2	82.3	95.0	106	116	125	134	142	150	157	164	171	177	184	190	196	201	207	212	217	223	228	232	237	242	247	251	256	260
		49	61.7	87.3	107	123	138	151	163	174	185	195	204	213	222	231	239	246	254	261	269	276	282	289	296	302	308	314	320	326	332	338
	80	55	77.7	110	135	156	174	190	205	220	233	245	257	269	280	291	301	311	320	330	339	347	356	364	373	381	388	396	404	411	418	426
		61	95.6	135	166	191	214	234	253	270	287	302	317	331	344	358	370	382	394	405	417	427	438	448	458	468	478	487	497	506	515	524
	100	69	122	173	212	245	274	299	323	346	367	387	406	424	441	458	474	489	504	519	533	547	561	574	587	599	612	624	636	647	659	670
		76	149	210	257	297	332	363	392	420	445	469	492	514	535	555	575	594	612	630	647	664	680	696	712	727	742	757	771	785	799	813
	125	86	190	269	329	380	425	465	503	537	570	601	630	658	685	711	736	760	784	806	829	850	871	892	912	931	950	969	988	1000	1020	1040
		95	232	328	402	464	519	568	614	656	696	733	769	803	836	868	898	928	956	984	1010	1030	1060	1080	1110	1130	1160	1180	1200	1220	1240	1270
SF-20 (2~3MPa)	150	105	284	401	491	567	634	694	750	801	850	896	940	982	1020	1060	1090	1130	1160	1200	1230	1260	1290	1320	1350	1380	1410	1440	1470	1500	1520	1550
		115	340	481	589	680	760	833	899	961	1020	1070	1120	1170	1220	1270	1310	1360	1400	1440	1480	1520	1550	1590	1630	1660	1700	1730	1760	1790	1830	1860

P: Relieving pressure (MPa), dt: Throat dia. (mm)

*1. Coefficient K and Accumulation are different according to types.

*2. P (MPa), which is for actual calculation to decide discharge amount, is (P)+(Accumulation)–(Back pressure)

■ LIFT TYPE

$$W=161 \times AK\sqrt{PG} \quad (K=0.55, G=1, \text{Accumulation } 10\% \text{ } A=\pi D^2)$$

(10³kg/h)

Size mm	D	Set pressure MPa	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0
15	15		0.552	0.780	0.956	1.10	1.23	1.35	1.46	1.56	1.65	1.74	1.83	1.91	1.99	2.06	2.13	2.20	2.27	2.34	2.40	2.46	2.53	2.58	2.64	2.70	2.76	2.81	2.86	2.92	2.97	3.02
20	20		0.922	1.30	1.59	1.84	2.06	2.25	2.43	2.60	2.76	2.91	3.05	3.19	3.32	3.45	3.57	3.68	3.80	3.91	4.01	4.12	4.22	4.32	4.42	4.51	4.61	4.70	4.79	4.87	4.96	5.05
25	25		1.61	2.28	2.79	3.22	3.60	3.94	4.26	4.56	4.83	5.09	5.34	5.58	5.81	6.03	6.24	6.44	6.64	6.84	7.02	7.21	7.38	7.56	7.73	7.89	8.06	8.22	8.37	8.53	8.68	8.83
32	32		2.35	3.33	4.08	4.71	5.27	5.77	6.23	6.67	7.07	7.45	7.82	8.16	8.50	8.82	9.13	9.43	9.72	10.0	10.2	10.5	10.8	11.0	11.3	11.5	11.7	12.0	12.2	12.4	12.6	12.9
40	40		3.68	5.21	6.38	7.37	8.24	9.03	9.75	10.4	11.0	11.6	12.5	12.7	13.2	13.8	14.2	14.7	15.2	15.6	16.0	16.4	16.9	17.3	17.6	18.0	18.4	18.8	19.1	19.5	19.8	20.2
50	50		5.99	8.47	10.3	11.9	13.4	14.6	15.8	16.9	17.9	18.9	19.8	20.7	21.6	22.4	23.2	23.9	24.7	25.4	26.1	26.8	27.4	28.1	28.7	29.3	29.9	30.5	31.1	31.7	32.2	32.8
65	65		10.1	14.4	17.6	20.3	22.7	24.9	26.9	28.8	30.5	32.2	33.7	35.2	36.7	38.1	39.4	40.7	42.0	43.2	44.4	45.5	46.6	47.7	48.8	49.9	50.9	51.9	52.9	53.9	54.8	55.8
75	75		13.1	18.5	22.7	26.2	29.3	32.1	34.7	37.1	39.4	41.5	43.5	45.5	47.3	49.1	50.8	52.5	54.1	55.7	57.2	58.7	60.2	61.6	63.0	64.3	65.6	66.9	68.2	69.5	70.7	71.9
80	78.4		14.4	20.4	25.0	28.9	32.3	35.4	38.2	40.8	43.3	45.7	47.9	50.0	52.1	54.0	55.9	57.8	59.6	61.3	63.0	64.6	66.2	67.8	69.3	70.8	72.2	73.7	75.1	76.5	77.8	79.1
100	100		22.9	32.4	39.6	45.8	51.2	56.1	60.6	64.8	68.7	72.4	75.9	79.3	82.6	85.7	88.7	91.6	94.4	97.2	99.8	102	105	107	109	112	114	116	119	121	123	125
	99.4		23.0	32.6	39.9	46.1	51.5	56.4	60.9	65.2	69.1	72.9	76.4	79.8	83.1	86.2	89.2	92.2	95.0	97.8	100	103	105	108	110	112	115	117	119	121	124	126
125	125		36.8	52.1	63.8	73.7	82.4	90.3	97.5	104	110	116	122	127	132	138	142	147	152	156	160	164	169	173	176	180	184	188	191	195	198	202
	130		39.5	55.9	68.5	79.1	88.4	96.9	104	111	118	125	131	137	142	148	153	158	163	167	172	176	181	185	189	193	197	201	205	209	213	216
150	150		52.5	74.3	91.0	105	117	128	139	148	157	166	174	182	189	196	203	210	216	223	229	235	240	246	252	257	262	268	273	278	283	287
	160		59.0	83.4	102	118	131	144	156	166	177	186	195	204	212	220	228	236	243	250	257	263	270	276	283	289	295	300	306	312	317	323

P: Relieving pressure (MPa), D: Seat opening dia. (mm), R: Lift (A)

*1. Coefficient K, Accumulation and Lift are different according to types.

*2. Refer to Page 65 for safety relief valves (SL-37~40, 39F, 40F, 43, 44 Type).

*3. P (MPa), which is for actual calculation to decide discharge amount, is (P)+(Accumulation)–(Back pressure)

*4. The relieving capacity of safety relief valves (SL-37~40, 39F, 40F Type (Page 62~64) and SL-43, 44 Type (Page 66)) are different from the values in this table.